

Heat Exchangers, ASME Pressure Vessels & Tanks

HYDROSTATIC TEST CERTIFICATION

DATE: 5-27-2010

The following reference pressure vessel(s) were successfully hydrostatically tested in accordance with the ASME Code Section VIII, Section 1.

JOHANSING JOB #: 6528

CUSTOMER: Lawrence Bereley National Labs

PURCHASE ORDER #: 6922618

NATIONAL BOARD #: N/A

VESSEL SERIAL #: 6528

GAUGE #: 3259

GAUGE RANGE: 0-2000

GAUGE CALIBRATION DATE: 5-6-2010

HYDROSTATIC TEST PRESSURE: 550 PSI


VESSEL DESCRIPTION: 1 1/4" OD 304 S/S Pipe Spool x 10.0"

OTHER: _____

2955 Ford St.
Oakland, CA 94601

(510) 261-1800
FAX (510) 261-1870

CERTIFIED BY: 
Quality Control Manager, Johansing Iron Works, Inc.

WITNESS BY:  Name: Derek Shuman
signature print name
Tom Miller

TITLE: _____